QINGDAO ORPHILA MEDICAL TECHNOLOGY CO., LIMITED
RM0501,FUTAI SQUARE NO18 HONGKONG MIDDLE ROAD,QINGDAO SHANDONG,CHINA

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description	:	(A)Children Mask
Composition	:	(A)60% Nonwoven,40%Melt-Blown Fabric
Sample Color	:	(A)White
Style No.	:	OM-M145-W
Lot No.	:	2020102703
Manufacturer	:	Qingdao Orphila Medical Technology Co., Limited.West Coast Branch
Test Performed	:	Selected test(s) as requested by applicant
Sample Receiving Date	:	Nov 02, 2020
Testing Period	:	Nov 03, 2020 - Nov 16, 2020
Test Result(s)	:	Unless otherwise stated the results shown in this test report refer only to the sample(s) tested, for further details, please refer to the following page(s).

Signed for and on behalf of
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd Testing Center

Sara Guo (Account Executive)

Dongjing Liu / Hailian Xuan (Authorized Signatory)

3rd Building,No.889,Yishan Road,Xuhui District Shanghai,China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgsgroup.com.cn
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com

Test Result

EN 14683:2019+AC:2019 Medical Face Masks-Requirements and Test Methods

Clause 5.2 Performance Requirement

Clause 5.2.2 Bacterial Filtration Efficiency (BFE)
(EN 14683:2019+AC:2019 Annex B)

Sample: A

Test Side	:	Inside
Test Area	:	Approximately 60 cm^2
Flow Rate	:	28.3 L/min
Pre-Conditioning	:	Minimum of 4 hours at 21±5°C and 85±5% R.H.
Dimensions of test specimen	:	~140mm x 155mm
Positive Control Average	:	2167 CFU
Negative Monitor Count	:	< 1 CFU
Mean Particle Size	:	3.0 ±0.3μm
Test bacteria	:	Staphylococcus aureus ATCC 6538

Test Item	Specimen No.	Result
Bacterial Filtration Efficiency (BFE)	1	99.2%
	2	99.4%
	3	99.2%
	4	99.7%
	5	99.4%

Remark:
1) Performance Requirement: Type I⩾95%, Type II⩾98%, Type IIR ⩾98%
2) The number of specimens that shall be tested is minimum 5, but can be greater and shall be increased if necessary to allow for an AQL(Acceptable Quality Level) of 4%.

3rd Building,No.889,Yishan Road,Xuhui District Shanghai,China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgsgroup.com.cn
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com

Clause 5.2.3 Breathability
(EN 14683 :2019+AC:2019 Annex C)

Sample: A
Test Side : Randomly test in different location (1 around and 4 away from the centric point) on each of the 5 masks
Pre-Conditioning : Minimum of 4 hours at 21±5°C and 85±5% R.H.
Test Area : 4.9 cm^2
Flow Rate : 8 l/min

Specimen No.	Test Area No.	Different Pressure for each tested area (Pa/cm^2)	The average value for each test specimen (Pa/cm^2)
1	1-1	34.9	36
	1-2	33.1	
	1-3	35.3	
	1-4	36.1	
	1-5	38.2	
2	2-1	33.5	35
	2-2	32.8	
	2-3	34.2	
	2-4	38.7	
	2-5	33.4	
3	3-1	33.7	38
	3-2	36.4	
	3-3	38.1	
	3-4	39.7	
	3-5	39.9	
4	4-1	34.5	36
	4-2	34.6	
	4-3	30.6	
	4-4	39.5	
	4-5	39.0	
5	5-1	32.9	36
	5-2	35.5	
	5-3	33.4	
	5-4	39.2	
	5-5	39.7	

Remark:
1) Performance Requirement: Type I<40 Pa/cm^2, Type II<40 Pa/cm^2, Type IIR<60 Pa/cm^2
2) The number of specimens that shall be tested is minimum 5, but can be greater and shall be increased if necessary to allow for an AQL(Acceptable Quality Level) of 4%.

3rd Building,No.889,Yishan Road,Xuhui District Shanghai,China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgsgroup.com.cn
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com

Clause 5.2.5 Microbial Cleanliness
(EN 14683:2019+AC:2019 Annex D and EN ISO 11737-1:2018)

Sample: A

Test Specimen#	Mask Weight(g)	Total Bioburden, (CFU/mask)	Total Bioburden, (CFU/g)
1#	2.76	<3	<1.09
2#	2.75	<3	<1.09
3#	2.68	6	2.24
4#	2.71	6	2.21
5#	2.73	6	2.20

Remark: Performance Requirement: Type I≤30 CFU/g, Type II≤30 CFU/g, Type IIR≤30 CFU/g

Sample Photo



The statement of conformity in this test report is only based on measured values by the laboratory and does not take their uncertainties into consideration.

End of Report

3rd Building,No.889,Yishan Road,Xuhui District Shanghai,China 200233 t (86-21) 61402666 f (86-21) 64958763 www.sgsgroup.com.cn
中国·上海·徐汇区宜山路889号3号楼 邮编: 200233 t (86-21) 61402666 f (86-21) 64958763 e sgs.china@sgs.com